

*India Office,
8th February, 1937.*

The KING has been pleased to appoint Sir George Cunningham, K.C.S.I., K.C.I.E., O.B.E., Indian Civil Service, to be Governor of the North West Frontier Province in succession to Sir Ralph Edwin Hotchkiss Griffith, K.C.S.I., C.I.E.

*India Office,
8th February, 1937.*

The KING has been pleased to appoint Sir Robert Niel Reid, K.C.S.I., K.C.I.E., Indian Civil Service, to be Governor of Assam in succession to Sir Michael Keane, K.C.S.I., C.I.E., Indian Civil Service.

*India Office,
8th February, 1937.*

The KING has been pleased to appoint Sir Maurice Garnier Hallett, K.C.S.I., C.I.E., Indian Civil Service, to be Governor of Bihar in succession to Sir James David Sifton, K.C.S.I., K.C.I.E., Indian Civil Service.

ELECTRICITY (SUPPLY) ACTS, 1882 to 1936.

The Electricity Commissioners hereby give notice that for the purposes of the above-mentioned Acts and of all Orders made or granted and issued thereunder, and of any local Act relating to the supply of electricity, they have approved of the construction and pattern of the meters hereinafter described and also the means provided for fixing the said meters and for connecting them with the service lines.

Meters manufactured by A.E.G. Electric Company Limited.

(i) Meter known as the A.E.G. Type J6 Single Phase Watthour Meter; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 20th July, 1936.)

(ii) Meter known as the A.E.G. Type J6* Single Phase Watthour Meter; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 20th July, 1936.)

(iii) Meter known as the A.E.G. Single Phase Prepayment Watthour Meter Type S2J6; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(iv) Meter known as the A.E.G. Single Phase Prepayment Watthour Meter Type S2J6*; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(v) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour

Meter Type FS2J6; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(vi) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour Meter Type FS2J6*; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(vii) Meter known as the A.E.G. Single Phase Prepayment Watthour Meter, Type SJ6; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(viii) Meter known as the A.E.G. Single Phase Prepayment Watthour Meter Type SJ6*; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(ix) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour Meter Type FSJ6; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(x) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour Meter Type FSJ6*; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(xi) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour Meter Type FS1J6; rated sizes 5, 10 and 20 amperes at 200 to 240 volts and 220 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

(xii) Meter known as the A.E.G. Single Phase Two Part Tariff Prepayment Watthour Meter Type FS1J6*; rated sizes 5, 10 and 20 amperes at 200 to 220 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 1st August, 1936.)

Meters manufactured by British Electric Meters Limited.

(i) Meter known as the British Electric Meters Type K Single Phase Watthour Meter; rated sizes 2½, 5, 10, 20 and 50 amperes at 230 volts; for constant pressure 2-wire single phase 50 cycle A.C. systems. (Approved 7th April, 1936. The approval in this case was in supersession of an approval dated 13th December, 1935.)

(ii) Meter known as the British Electric Meters Type K Single Phase Watthour Meter; rated sizes 2½, 5, 10, 20, 40 and 50 amperes at 200 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 30th December, 1936. The approval in this case was in supersession of an approval dated 7th April, 1936 (see (i) above).)

(iii) Meter known as the British Electric Meters Type N.C. Single Phase Watthour Meter; rated size 20 amperes at 200 to 250 volts; for constant pressure 2-wire single phase 50-cycle A.C. systems. (Approved 11th January, 1937.)