

Board of Trade, Millbank, London, S.W.1.

January 3, 1950.

The Board of Trade hereby give notice that they have made Orders which have been published as S.I.'s 1949, price 1d. except where stated:—

No. 2308. The Safeguarding of Industries (Lists of Dutiable Goods) (Consolidation and Amendment) Order, 1949 dated 12th December, 1949 (Price 1s. 0d.)

No. 2338. The Patents Etc. (Singapore) Order, 1949 dated 15th December, 1949.

No. 2362. The Imported Hardwood Prices (Revocation) Order, 1949 dated 19th December, 1949.

No. 2367. The Copyright (Industrial Designs) Rules, 1949 dated 16th December, 1949.

No. 2381. The Sale of Food (Weights and Measures: Variation of First Schedule) Regulations, 1949 dated 19th December, 1949.

No. 2382. The Plywood Prices (No. 2) Order, 1949 dated 20th December, 1949 (Price 6d.).

No. 2385. The Patents Rules, 1949 dated 16th December, 1949 (Price 1s. 9d.).

No. 2390. The Weights and Measures (Board of Trade Standard 1 hundredweight, 4 hundredweights, 5 hundredweights and 10 hundredweights) Order, 1949 dated 21st December, 1949.

No. 2415. The Gloves (Manufacture and Supply) (Amendment No. 3) Order, 1949 dated 22nd December, 1949 (Price 3d.).

No. 2416. The Control of Growing Trees and Home-Grown Round Timber in the Log (Revocation) Order, 1949 dated 22nd December, 1949.

No. 2417. The Utility Mark and Apparel and Textiles (General Provisions) (Amendment No. 5) Order, 1949 dated 22nd December, 1949.

These Orders can be purchased through any bookseller, agents, or direct from His Majesty's Stationery Office at the following addresses:—York House, Kingsway, London, W.C.2; 13a Castle Street, Edinburgh, 2; 39 King Street, Manchester, 2; 2 Edmund Street, Birmingham, 3; 1 St. Andrew's Crescent, Cardiff; Tower Lane, Bristol, 1; 80 Chichester Street; Belfast.

#### PETROLEUM (PRODUCTION) ACT, 1934.

The Minister of Fuel and Power hereby gives notice that he has renewed for a further term of twelve months, three prospecting licences granted under the Petroleum (Production) Act, 1934, and Petroleum (Production) Regulations, 1935, to the D'Arcy Exploration Company Limited, Britannic House, Finsbury Circus, London, E.C.2. The areas concerned cover about 310 square miles in the Counties of Dorset, Wiltshire and Hampshire (including Isle of Wight).

Maps showing the boundaries of the areas may be inspected on application to the Ministry of Fuel and Power, Petroleum Division, 7 Millbank, London, S.W.1.

3rd January, 1950.

#### ELECTRICITY ACT, 1947.

##### ELECTRICITY (SUPPLY) ACTS, 1882 TO 1936.

The Minister of Fuel and Power hereby gives notice that for the purposes of the above mentioned Acts and of all Orders made, granted and issued thereunder and of any Local Act relating to the supply of electricity, the construction and pattern of the meters hereinafter described and also the means for fixing the said meters and for connecting them with the service lines, have been approved since the last similar notice published by the Electricity Commissioners in the London Gazette dated 19th December, 1947.

The Approvals dated prior to the 1st April, 1948, the Vesting Date for the purposes of the Electricity Act, 1947, were given by the Electricity Commissioners and those after that date were given by the Minister of Fuel and Power.

A. Approvals limited to meters manufactured at any time up to the expiration of a period of three years from the date of approval and not further or otherwise. In each case the right is reserved to the Minister of Fuel and Power to renew the approvals at the expiration of the said three years for such period and upon such conditions as he may think fit.

Meters manufactured by British Electric Meters Ltd.

Meters known as:—

(1) British Electric Meters Type K3T Polyphase Two-Element Watthour Meter; rated sizes 2½, 5, 10, 20, 25, 40 and 50 amperes at 100/130, 200/250 and 346/440 volts; for constant voltage 3-wire single phase, 3 or 4-wire two phase and 3-wire 3-phase 50 cycle A.C. systems. (Approved 6th May, 1949.)

(2) British Electric Meters Type KT1 Single Phase Watthour Meter; rated sizes 5 L.R., 10 L.R., 20 L.R., 25 L.R. and 50 L.R. amperes at 200/250 and 346/440 volts; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 11th May, 1949.)

(3) British Electric Meters Type TM1 Single Phase Watthour Meter; rated sizes 2½ L.R., 5 L.R., 10 L.R., 25 L.R., 5, 10 and 20 amperes at 100/130, 200/250 and 346/440 volts; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 3rd October, 1949. The three-year period in this case is dated from 29th July, 1949. This approval is in supersession of approval dated 29th July, 1949.)

Meters manufactured by British Insulated Callender's Cables Ltd.

Meter known as:—

British Insulated Callender's Cables Type LBT Single Phase Prepayment Watthour Meter; rated sizes 2½ L.R., 5 L.R., 10 L.R., 20 L.R. and 25 L.R. amperes at 200/250 volts; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 27th January, 1948.)

Meters manufactured by Chamberlain and Hookham Ltd.

Meters known as:—

(1) Chamberlain and Hookham Type K Sinele Phase Watthour Meter; rated sizes 5 L.R., 10 L.R., 25 L.R. and 50 L.R. amperes at any one marked voltage within the limits 84 to 150, 168 to 300 and 336 to 750 volts inclusive; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 22nd May, 1947.)

(2) Chamberlain and Hookham Types JTU, JTDU and JTSU Three Phase Three Wire Watthour Meters; rated sizes 100, 150 and 200 amperes at 100/125, 200/250, 340/425, 400/500 volts or any one marked voltage from 50 volts to 650 volts inclusive; for constant voltage 3-wire 3-phase 50 cycle A.C. systems. (Approved 20th October, 1948.)

(3) Chamberlain and Hookham Types JTRU, JTDRU and JTSRU Three Phase Three Wire Two Rate Watthour Meters; rated sizes 100, 150 and 200 amperes at 100/125, 200/250, 340/425, 400/500 volts or any one marked voltage from 50 volts to 650 volts inclusive; for constant voltage 3-wire 3-phase 50 cycle A.C. systems. (Approved 20th October, 1948.)

(4) Chamberlain and Hookham Types JT4U, JT4DU and JT4SU Three Phase Four Wire Watthour Meters; rated sizes 100, 150 and 200 amperes at 100/125, 200/250 volts or any one marked voltage from 90 volts to 260 volts inclusive; for constant voltage 4-wire 3-phase 50 cycle A.C. systems. (Approved 20th October, 1948.)

(5) Chamberlain and Hookham Types JT4RU, JT4DRU and JT4SRU Three Phase Four Wire Two Rate Watthour Meters; rated sizes 100, 150 and 200 amperes at 100/125, 200/250 volts or any one marked voltage from 90 volts to 260 volts inclusive; for constant voltage 4-wire 3-phase 50 cycle A.C. systems. (Approved 20th October, 1948.)

Meters manufactured by Crompton Parkinson Limited.

Meters known as:—

(1) Crompton Parkinson Type AL/2 Single Phase Watthour Meter; rated sizes 2½ L.R., 5 L.R., 10 L.R., 25 L.R. and 50 L.R. amperes at 100/125, 200/250 and 400/450 volts; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 12th May, 1947.)

(2) Crompton Parkinson Type B Single Phase Watthour Meter; rated sizes 2½ L.R., 5 L.R., 10 L.R., 25 L.R. and 50 L.R. amperes at 100/125 and 200/250 volts; for constant voltage 2-wire single phase 50 cycle A.C. systems. (Approved 5th July, 1948.)

(3) Crompton Parkinson Type BI Single Phase Watthour Meter; rated sizes 2½ L.R., 5 L.R., 10 L.R., 25 L.R. and 50 L.R. amperes at 100/125 and 200/250 volts; for constant voltage 2-wire