

The general effect of this Order is that for a period of six months from the 6th August 1976 the Authority may:

1. Abstract water from the River Wye at a rate of 3411 cubic metres per day at a point of abstraction on the eastern bank of the said river in the parish of Walford in the county of Hereford and Worcester at National Grid Reference SO58411973.
2. Maintain an intake at the said point of abstraction together with a line of pipes, commencing at the said intake, in or on the land and approximately along the line shown in red on the deposited plan, and terminating at the existing treatment works at Castle Brook.
3. Enter upon, occupy and use the land through which the line of pipes referred to in (2) above passes to such extent and in such manner as may be necessary for the maintenance of the works authorised.
4. The Authority shall before exercising the powers of entry contained in (4) above give to every owner and occupier of the land in question not less than 7 days notice of the intended entry on the land.

The Order came into operation on the 6th August 1976 and will be operative until the 5th February 1977. A copy of this Order is deposited at the Authority's Headquarters' Office, Cambrian Way, Brecon, Powys, and at the offices of the Hereford Water Division of the Authority at Reay House, Bodenham Road, Hereford, and may be inspected at any time during normal office hours.

Dated 13th August 1976.

(775) *H. H. Crann*, Chief Executive.

WELSH NATIONAL WATER DEVELOPMENT AUTHORITY

(Llyn Cwellyn) (Drought) Order 1976

Notice is hereby given that in exercise of the powers conferred upon him by section 1 of the Drought Act 1976 the Secretary of State for Wales on the 11th August 1976 made the above mentioned Order.

The general effect of this Order is to enable the Authority, for a period of six months, to:

- (1) abstract up to 3.1 million gallons of water per day from Llyn Cwellyn to be discharged into the Afon Gwyrfai to maintain abstraction at the Nant Mill intake authorised by Licences Numbers 23/65/15/5A and 23/65/15/5;
- (2) amend the provisions of clause 7 (A) of the Schedule to Licence Number 23/65/15/5A so that for the minimum prescribed flow of water at the point designated in the said clause for 3 million gallons per day there shall be substituted a figure of 2 million gallons per day;
- (3) for that purpose to enter on, occupy and use land being enclosure Number 566 on O.S. Sheet SH55NE at Grid Reference SH5520557 owned and occupied by Mr. and Mrs. W. Thurley at Cwm Bychan Farm, Bettws Garmon, Gwynedd, in order to install, use and maintain two pumps and two mobile diesel generators and associated equipment to enable the water to be abstracted from Llyn Cwellyn and pumped into the Afon Gwyrfai.

The Order came into operation on 12th August 1976 and will be operative until and including 11th February 1977. A copy of this Order is deposited at the Authority's Headquarters' Office at Cambrian Way, Brecon, Powys and at the office of the Gwynedd River Division of the Authority at Highfield, Priestley Road, Caernarvon, Gwynedd, LL55 1HR and may be inspected at any time during normal office hours.

Dated 13th August 1976.

(776) *H. H. Crann*, Chief Executive.

WELSH NATIONAL WATER DEVELOPMENT AUTHORITY

Drought Act 1976

Notice is hereby given that whereas Licence No. 24/66/5/4/S granted under the provisions of the Water Resources Act 1963 provides that the Welsh National Water Development Authority (hereinafter referred to as "the Authority") may abstract water from the Afon Aled at grid reference SH 957 704 at the rate of up to 6,000,000 gallons per day provided that no abstraction shall be made which will have the effect of reducing the residual flow

in the Afon Aled as measured at the Bryn Aled Weir ("the Weir") immediately downstream of the abstraction point to less than 4,000,000 gallons per day and when the abstraction rate exceeds 4,000,000 gallons per day the residual flow in the Afon Aled as measured at the Weir shall not be less than the abstraction rate.

Notice is hereby given that the Authority, because of exceptional shortage of rain, in pursuance of powers contained in section 1 of the Drought Act 1976 is about to apply to the Secretary of State for Wales for an Order, the general effect of which would be that for a period not exceeding six months or until such time as the Llyn Aled and Aled Isaf Reservoirs shall become full, whichever is the sooner, the Authority

- (1) may reduce the minimum residual flow in the Afon Aled as measured at the Weir from 4,000,000 gallons per day to 2,500,000 gallons per day;
- (2) when the level of the Llyn Aled Reservoir drops below the minimum draw off level, may pump water at a maximum rate of 5,000,000 gallons per day from that Reservoir into the Aled Isaf Reservoir by means of a pump situate at grid reference SH 915 579 on land owned by the Authority.

A copy of the relevant plan showing the point at which a pump shall be situated to discharge water from the Llyn Aled Reservoir to the Afon Aled, the point of abstraction and the Weir may be inspected by any person free of charge at all reasonable hours within a period of 7 days from the date of service/publication of this notice at the offices of the Authority's Dee and Clwyd Water Division at Chester Road, Flint and "Plastirion", 91 Russell Road, Rhyl, Clwyd.

Any objection to the proposed Order should be made in writing to the Secretary of State, Welsh Office, Pearl Assurance House, Greyfriars Road, Cardiff, CF1 3RT, within 7 days of the date of service/publication of this notice, quoting reference LG/WS/3453/77 and should state the grounds of the objection.

It is requested that a copy of the notice may at the same time be sent to the undersigned.

H. H. Crann, Chief Executive.

Cambrian Way, Brecon,
Powys, LD3 7HP.

(778)

WELSH NATIONAL WATER DEVELOPMENT AUTHORITY

DROUGHT ACT 1976

Notice is hereby given that whereas Licence No. 24/66/5/4/S granted under the provisions of the Water Resources Act 1963 provides that the Welsh National Water Development Authority (hereinafter referred to as "the Authority") may abstract water from the Afon Aled at grid reference SH 957 704 at the rate of up to 6,000,000 gallons per day provided that no abstraction shall be made which will have the effect of reducing the residual flow in the Afon Aled as measured at the Bryn Aled Weir ("the Weir") immediately downstream of the abstraction point to less than 4,000,000 gallons per day and when the abstraction rate exceeds 4,000,000 gallons per day the residual flow in the Afon Aled as measured at the Weir shall not be less than the abstraction rate.

Notice is hereby given that the Authority, because of exceptional shortage of rain, in pursuance of powers contained in section 1 of the Drought Act 1976 is about to apply to the Secretary of State for Wales for an Order, the general effect of which would be that for a period not exceeding six months or until such time as the Llyn Aled and Aled Isaf Reservoirs shall become full, whichever is the sooner, the Authority

- (1) may reduce the minimum residual flow in the Afon Aled as measured at the Weir from 4,000,000 gallons per day to 2,500,000 gallons per day;
- (2) when the level of the Llyn Aled Reservoir drops below the minimum draw off level, may pump water at a maximum rate of 5,000,000 gallons per day from that Reservoir into the Aled Isaf Reservoir by means of a pump situate at grid reference SH 915 579 on land owned by the Authority.

A copy of the relevant plan showing the point at which a pump shall be situated to discharge water from the Llyn Aled Reservoir to the Afon Aled, the point of abstraction and the Weir may be inspected by any person free of charge at all reasonable hours within a period of 7 days from the date of service/publication of this notice at the