

Severn Trent Water Limited has failed to complete the installation of treatment plant to reduce lead concentrations in zones supplied by this works by 31st December 1995, and the Secretary of State for the Environment has proposed to require completion of the installation within 28 days.

Notice under section 20, Water Industry Act 1991

The Secretary of State for the Environment hereby gives notice as required by section 20(1) of the Water Industry Act 1991 to Severn Trent Water Limited "the Company" that:

- (1) he proposes to make a Final Enforcement Order under section 18 of the Water Industry Act 1991, requiring the Company within 28 days of the date of the Order to complete installation of treatment plant at six sites where such treatment is appropriate to avoid the risk of exceeding the prescribed concentration of lead in water after leaving the Company's pipes;
- (2) the proposed Order is made for the purpose of securing compliance with Regulation 24 of the Water Supply (Water Quality) Regulations 1989 "the 1989 Regulations", and with an Undertaking given by the Company on 12th September 1989 under section 20 of the Water Act 1989, now section 19 of the Water Industry Act 1991, "the Undertaking", that where such treatment was appropriate, it would be installed by the end of December 1995;
- (3) at the six sites identified in the Order, namely August/Ryon Hill water treatment works, Ladderedge service reservoir (previously to be installed at Wallgrange water treatment works), Oswestry high level water treatment works, Oswestry low level water treatment works, Shootershill service reservoir and Waveley Road water treatment works, the Company had, as at 9th January 1996, failed to complete installation of appropriate treatment as required by the Undertaking;
- (4) the Secretary of State is therefore satisfied that there is a risk that water supplied by the Company in the zones supplied from the sites identified in the Order would cease to comply with the requirements of Part II of the 1989 Regulations after leaving the Company's pipes by reason of the presence in the water of a concentration of lead which exceeds the prescribed concentration and which is attributable to the fact that lead is a major component of service pipes, and that the Company has not treated the water as required by Regulation 24(1)(a) of the 1989 Regulations;
- (5) representations or objections with respect to the proposed Order may be made within 28 days from the date of publication of this notice, and should be addressed to:

O. Hydes, Deputy Chief Inspector, Drinking Water Inspectorate, Room B148B, Romney House, 43 Marsham Street, London SW1 3PY. (Ref. E1239/01/DWI).

A copy of the proposed Order can be obtained from the above address. (1 SI)

SEVERN TRENT WATER LIMITED

WATER INDUSTRY ACT 1991, SECTION 20

The following notice affects consumers of Severn Trent Water Limited in the Coventry City and Whitley areas in zones supplied by Waveley Road water treatment works.

Severn Trent Water Limited has failed to complete the installation of treatment plant to reduce lead concentrations in zones supplied by this works by 31st December 1995 and the Secretary of State for the Environment has proposed to require completion of the installation within 28 days.

Notice under section 20, Water Industry Act 1991

The Secretary of State for the Environment hereby gives notice as required by section 20(1) of the Water Industry Act 1991 to Severn Trent Water Limited "the Company" that:

- (1) he proposes to make a Final Enforcement Order under section 18 of the Water Industry Act 1991 requiring the Company within 28 days of the date of the Order to complete installation of treatment plant at six sites where such treatment is appropriate to avoid the risk of exceeding the prescribed concentration of lead in water after leaving the Company's pipes;
- (2) the proposed Order is made for the purpose of securing compliance with Regulation 24 of the Water Supply (Water Quality) Regulations 1989 "the 1989 Regulations", and with an Undertaking given by the Company on 12th September 1989 under section 20 of the Water Act 1989, now section 19 of the Water Industry Act 1991, "the Undertaking", that where such

treatment was appropriate, it would be installed by the end of December 1995;

- (3) at the six sites identified in the Order, namely August/Ryon Hill water treatment works, Ladderedge service reservoir (previously to be installed at Wallgrange water treatment works), Oswestry high level water treatment works, Oswestry low level water treatment works, Shootershill service reservoir and Waveley Road water treatment works, the Company had, as at 9th January 1996, failed to complete installation of appropriate treatment as required by the Undertaking;
- (4) the Secretary of State is therefore satisfied that there is a risk that water supplied by the Company in the zones supplied from the sites identified in the Order would cease to comply with the requirements of Part II of the 1989 Regulations after leaving the Company's pipes by reason of the presence in the water of a concentration of lead which exceeds the prescribed concentration and which is attributable to the fact that lead is a major component of service pipes, and that the Company has not treated the water as required by Regulation 24(1)(a) of the 1989 Regulations;
- (5) representations or objections with respect to the proposed Order may be made within 28 days from the date of publication of this notice, and should be addressed to:

O. Hydes, Deputy Chief Inspector, Drinking Water Inspectorate, Room B148B, Romney House, 43 Marsham Street, London SW1 3PY. (Ref. E1240/01/DWI.)

A copy of the proposed Order can be obtained from the above address. (2 SI)

SEVERN TRENT WATER LIMITED

WATER INDUSTRY ACT 1991, SECTION 20

The following notice affects consumers of Severn Trent Water Limited in the Rushton, Leek, Bidulph, Endon, Chell Norton, Tunstall Kildgrove, Burrem, Hanley, Stoke-on-Trent City and Newcastle-under-Lyme areas in zones supplied by Ladderedge Service Reservoir water treatment works.

Severn Trent Water Limited has failed to complete the installation of treatment plant to reduce lead concentrations in zones supplied by this reservoir by 31st December 1995 and the Secretary of State for the Environment has proposed to require completion of the installation within 28 days.

Notice under section 20, Water Industry Act 1991

The Secretary of State for the Environment hereby gives notice as required by section 20(1) of the Water Industry Act 1991 to Severn Trent Water Limited "the Company" that:

- (1) he proposes to make a Final Enforcement Order under section 18 of the Water Industry Act 1991 requiring the Company within 28 days of the date of the Order to complete installation of treatment plant at six sites where such treatment is appropriate to avoid the risk of exceeding the prescribed concentration of lead in water after leaving the Company's pipes;
- (2) the proposed Order is made for the purpose of securing compliance with Regulation 24 of the Water Supply (Water Quality) Regulations 1989 "the 1989 Regulations", and with an Undertaking given by the Company on 12th September 1989 under section 20 of the Water Act 1989, now section 19 of the Water Industry Act 1991, "the Undertaking", that where such treatment was appropriate, it would be installed by the end of December 1995;
- (3) at the six sites identified in the Order, namely August/Ryon Hill water treatment works, Ladderedge service reservoir (previously to be installed at Wallgrange water treatment works), Oswestry high level water treatment works, Oswestry low level water treatment works, Shootershill service reservoir and Waveley Road water treatment works, the Company had, as at 9th January 1996, failed to complete installation of appropriate treatment as required by the Undertaking;
- (4) the Secretary of State is therefore satisfied that there is a risk that water supplied by the Company in the zones supplied from the sites identified in the Order, would cease to comply with the requirements of Part II of the 1989 Regulations, after leaving the Company's pipes by reason of the presence in the water of a concentration of lead, which exceeds the prescribed concentration, and which is attributable to the fact that lead is a major component of service pipes, and that the Company has not treated the water as required by Regulation 24(1)(a) of the 1989 Regulations;